



**NOTES:**

1. WORKING CLEARANCE FROM ENERGIZED ANTENNA MUST BE GREATER THAN 4', OTHERWISE SHUT DOWN RADIO AND ANTENNA PER INSTRUCTIONS ON PLACARD OR BY OPENING DISCONNECT SWITCH TO RADIO EQUIPMENT ON POLE.
2. ANTENNA AND MOUNTING BRACKETS INSTALLED ABOVE DTE WIRES MUST BE INSTALLED AND MAINTAINED BY DTE OR DTE'S DESIGNATED CONTRACTOR.
3. VERTICAL CLIMBING ZONE MUST BE MAINTAINED ON ALL POLES (SEE TOP VIEW).
4. RADIO TO BE CLEARLY LABELED WITH OWNER'S NAME AND 1-800 PHONE NUMBER WITH 3/4" TALL LETTERING.
5. SHUTDOWN PLACARD TO BE PLACED ON THE POLE NEAR RADIO AND DISCONNECT SWITCH BOX.
6. 5' MIN CLEARANCE ABOVE ANY DTE EQUIPMENT MUST BE MAINTAINED.
7. ANTENNA POLE TOP CLEARANCES APPLY TO ANY DTE EQUIPMENT OR WIRES INSTALLED UNDER THE ANTENNA.
8. ALL FEEDS MUST FOLLOW DTE EASEMENTS AND CANNOT CROSS PRIVATE PROPERTY. NO BACK LOT FEEDS ACROSS PRIVATE PROPERTY WILL BE APPROVED.

R	REVISIONS		TITLE:			 <b>DTE Energy</b> <i>DTE Electric Company</i>		
	ORIGINATION	2017	CELLULAR ANTENNA SMALL CELL SITE CONSTRUCTION			BOOK 1	OH	LINE CONSTRUCTION STANDARDS
	LAST REVISION	10/16/2019				4 - JOINT USE		
	CYCLE	2017	PICTURE	BOM	VIDEO	ALL	STANDARD	1-4-26.1